



NOTES:

A	ALL MATERIALS ARE STAINLESS STEEL PER FEDERAL SPECIFICATION AND ASME B31.1 PER 15020-2.1
B	PIPE SUPPORT SHALL BE SUPPLIED BY PIPELINE PRODUCTS OR APPROVED EQUAL
C	IN EVENT SUPPORT IS MOUNTED ON CONCRETE SLAB OR FLOOR, PIER NOT REQUIRED

PICO WATER DISTRICT
ADJUSTABLE PIPE SUPPORT

APP. *Myra Ayala*
 PROJECT GENERAL NUMBER

STANDARD DRAWING NUMBER
W-32
 DATE: 08/27/2000